



COUNTY OF DANE
DEPARTMENT OF ADMINISTRATION
PURCHASING DIVISION

City County Building
210 Martin Luther King Jr. Blvd. Room 425
Madison, WI 53703-3345

GREG BROCKMEYER
Director of Administration

CHARLES HICKLIN
Controller

Date: April 6, 2021
To: All Proposers
Subject: Addendum #3 to RFP #121027 Audio Visual Upgrades at the City County Building

The Following questions were received and responses are provided:

1. For the auditorium plan E201-1 there is a reference to running new power circuits for number 3 and 4 to electrical panels in TR Room C. One is a normal power circuit on panel LP2-1 and the other is an emergency Power Circuit in the same room in Panel EM2-1 **Review Addendum #1**
 - a. Can you provide plans on where this room is? **Room is shown with referenced panels shown however additional circuits were removed in addendum 1**
 - b. Are the current wires run to this room today? **Existing condition is unknown**
 - c. How are you using the existing power and Emergency power? As a follow up how do you want this to function with the new wiring? **Plans do not call for any emergency power modifications or additions.**
 - d. Is number 4 on the drawing being used of AV or just new outlets for future use? **Keyed note 4 indicates existing to remain device**
 - e. Is there any Coring that is required in order to get to the panels labeled above? **Extending new circuits was removed in addendum 1.**
2. In Plan Labeled E301-1 rooms 357, 351 354, and 321 There are spots labeled PT representing Poke Through and request that we extend the current poke through circuit and that it be separated from the display circuits.
 - a. Are these rooms today on two separate circuits? **Existing circuiting condition unknown. Assume poke through are on separate circuit from wall mounted devices**
 - b. If they are not on separate circuits today can you provide electrical drawings for the current room circuits and the panels they are run to? **Assume at least 1 circuit supplying poke through and 1 circuit supplying wall devices exists in these rooms.**
 - c. Are the rooms that require the poke trough's are there existing Poke throughs in the room? **Yes**
 - d. Do we need to core the floor from underneath/What is the floor material? **The floor is concrete and will need to be cored for new devices. Work will be done during periods of low occupancy on nights 6P-5A and weekends) You will need to access bottom side of floor from ceiling space below.**
 - e. Do you have a preference for the type of floor box required in these rooms? **Legrand Evolution Series, 6" Device, surface cover with black powder coat finish**



GREG BROCKMEYER
Director of Administration

COUNTY OF DANE
DEPARTMENT OF ADMINISTRATION
PURCHASING DIVISION
City County Building
210 Martin Luther King Jr. Blvd. Room 425
Madison, WI 53703-3345

CHARLES HICKLIN
Controller

Please acknowledge receipt of this addendum by checking the "Addendum #3" box in **Section 6 – Required Forms – Attachment A - Vendor Information** of your proposal response. If you have questions regarding this addendum, please contact me via phone or email as listed below.

Sincerely,

Megan Rogan
Purchasing Officer
608-283-1487
rogan.megan@countyofdane.com