



COUNTY OF DANE
DEPARTMENT OF ADMINISTRATION
PURCHASING DIVISION
City County Building
210 Martin Luther King Jr. Blvd. Room 425
Madison, WI 53703-3345

GREG BROCKMEYER
Director of Administration

CHARLES HICKLIN
Controller

Date: August 5, 2022
To: All Proposers
Subject: Addendum #2 to RFB#122065 HMA Pavement – County Projects

The following questions were received and responses are provided:

- 1. CTH AB Project-Where is the concrete removal of 50 SY and what is it?**
There are several concrete driveways.
- 2. CTH AB Project- How far from the fog line do we mill into the driveways?**
The pavement will go out 15 ft from the centerline on each side.
- 3. CTH AB Project-Is there a weight restriction on the bridge?**
Standard highway weight limits apply.
- 4. CTH AB Project-For the southern section, will the widening be on both sides of AB?**
The current road width varies and is irregular. The finished road will be 30 ft wide. This will require widening of about 2-4 ft on the side away from the lake and about 1-4 ft on the lake side of CTH AB on the southern section.

Please acknowledge receipt of this addendum by checking the “Addendum #2” box on **Attachment A - Vendor Information** of your proposal response. If you have questions regarding this addendum, please contact me via phone or email as listed below.

Sincerely,

Carmen Hidalgo
Purchasing Agent
608-266-4966
Hidalgo.carmen@countyofdane.com